

RO temperature correction factor

Temperature °C / °F	Corr factor.	Temperature °C / °F	Corr factor.
0 / 32	0.672	13 / 55	1.000
1 / 34	0.695	14 / 57	1.028
2 / 36	0.719	15 / 59	1.055
3 / 37	0.742	16 / 61	1.084
4 / 39	0.766	17 / 63	1.112
5 / 41	0.790	18 / 64	1.142
6 / 43	0.816	19 / 66	1.170
7 / 45	0.842	20 / 68	1.200
8 / 46	0.866	21 / 70	1.229
9 / 48	0.893	22 / 72	1.259
10 / 50	0.919	23 / 73	1.289
11 / 52	0.946	24 / 75	1.319
12 / 54	0.973	25 / 77	1.350